

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/01/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155755		(X2) MULTIPLE CONSTRUCTION A. BUILDING 03 B. WING _____		(X3) DATE SURVEY COMPLETED 07/25/2013	
NAME OF PROVIDER OR SUPPLIER GOLDEN YEARS HOMESTEAD				STREET ADDRESS, CITY, STATE, ZIP CODE 3136 GOEGLEIN RD FORT WAYNE, IN 46815			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 07/25/13</p> <p>Facility Number: 000282 Provider Number: 155755 AIM Number: 100287520</p> <p>Surveyor: Amy Kelley, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, Golden Years Homestead was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility with a partial basement was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detectors in the corridors, spaces open to the corridors and in the resident rooms. The facility has a capacity of 106 and a census of 102 at the time of this survey.</p> <p>All areas where residents have customary access were sprinklered. The areas providing facility services included an unsprinklered detached garage used for the storage of mowing equipment and a golf cart.</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/01/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155755	(X2) MULTIPLE CONSTRUCTION A. BUILDING 03 B. WING _____		(X3) DATE SURVEY COMPLETED 07/25/2013
NAME OF PROVIDER OR SUPPLIER GOLDEN YEARS HOMESTEAD			STREET ADDRESS, CITY, STATE, ZIP CODE 3136 GOEGLEIN RD FORT WAYNE, IN 46815		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 07/31/13.	K 000			